

## 水 務 署 Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號

(2) in WSD 3321/2023 T/J(522/2023)

電話

Our ref. 來函檔號 Tel.

Your ref.

傳真

: 2824 0578

2 June 2023

Tradetech Supplies Limited 602, 6/F., Wing Fat Industrial Building, 12 Wang Tai Road, Kowloon Bay, Kowloon, Hong Kong

(Attn.: Mr Michael HAU)

Dear Sir,

## Approval of "WEILONG" Butterfly Valves (General Acceptance No. C20230389)

Your letter dated 18 May 2023 refers.

Having considered the test report ref. BC-SUMMARY-2023-070 issued on 11 May 2023 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Weflo Valve Co Ltd

**Country of Origin:** 

the Mainland of China

**Brand:** 

Weilong

**Details of Fittings:** 

Ductile iron wafer type butterfly valve with epoxy coating

under WRAS approval no. 2104506

Model:

2302

Size:

50mm, 65mm, 80mm, 100mm, 150mm, 200mm, 250mm

**Body Markings:** 

(DN) Model 2302

**Expiry Date:** 

30 April 2026





This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only