



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 3 ) in WSD 3321/2021 T/J(82/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

13 April 2021

Tradetech Supplies Limited  
Unit 16, 5/F., Kowloon Bay Industrial Centre,  
15 Wang Hoi Road, Kowloon Bay,  
Kowloon, Hong Kong

(Attn.: Mr Michael HAU)

Dear Sir,

**Approval of "LIGHTWAY" Expansion Joint  
(General Acceptance No. C20210379FS)**

Your letters dated 24 December 2020 and 15 March 2021 refer.

Having considered the test report ref. BC-SUMMARY-2020-158 issued on 16 November 2020 by Castco Testing Centre Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Light Way Metals Co Ltd  
**Country of Origin:** Taiwan, China  
**Brand:** Lightway  
**Details of Fitting:** 200mm Stainless steel expansion joint  
**Model:** JF-850SG(PN25)  
**Body Markings:** Model JF-850SG SS304 W/P 25 bar  
**Expiry Date:** 9 November 2025

**Proviso:** The fitting can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fitting in fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water fire services systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only